

Month

Year

V/R Daily Inspection Log
Must Be Kept Under Penalty of Law R20-2-909

Arizona Department of
 Weights and Measures
www.azdwm.gov

Vacuum Assist Systems

DISPENSERS	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
1. Nozzle Instruction & Oxygenate Decals posted & readable?																															
2. Weights & Measures number posted / readable? (602) 255-5211																															
3. Open Dispensers: Check for any leaks or drips.																															
4. Are all lights lit & all displays readable?																															
NOZZLES																															
1. Are spouts tight with no play?																															
2. Are spouts damaged - worn - or bent																															
3. Does the Trigger Work properly? Moves freely when dispenser off & no fuel can be dispensed?																															
4. Is the Nozzle dripping gasoline?																															
5. Does the hold open latch work properly?																															
6. Does the auto shut-off work properly?																															
HOSES																															
1. Are any hoses cut- crimped- torn flattened- frayed or more than 6" dragging on the ground?																															
2. Breakaway? Is any fuel leaking from the connections?																															
SWIVELS																															
1. Do all swivels move freely?																															
2. Are there any signs of binding or leaking?																															
UNDERGROUND STORAGE TANKS																															
1. Are spill buckets clean & dry?																															
2. Are the caps locked on securely? With gaskets in place?																															
3. With the caps on, can you turn the pipes?																															
4. Is the fill tube in good condition?																															
5. Are there any dents/ cracks in the fill tube?																															
6. Are gaskets between collar & drop tube? None torn- missing -out of place?																															
7. Are PV valves on the vent pipes? Are they damaged?																															
PERMITS																															
1. Are Permits and licenses posted/ readily available to Regulators?																															
2. Are Inspection & Maintenance logs CURRENT, COMPLETE & CORRECT?																															
3. Are originals/copies of the last 4 gas drops available to Regulators?																															

If you are having any problems with the above, immediately tag the equipment 'OUT of ORDER'.

Fill out the Owner Operator Repair/ Maintenance Log and contact Maintenance for repairs. The equipment must be tested by a licensed RSR in order to put the equipment back into service. According to A.A.C. R20-2-602 (B)(1)(c).

Owner Operator _____ Date _____

I certify this to be accurate and complete as required under A.A.C. R20-2-907 and R20-2-909 and I acknowledge that not maintaining or falsification of this document is a violation of this chapter and subject to civil penalties under A.R.S. 41-2115.